

SUBJECT: FAN CYCLE CONTROL CHANGE

Number: 15-03
Product: Cubers
Date Issued: May 11, 2015
From: Technical Service

Ice-O-Matic has made a modification to the cuber product line. The supplier for the Fan Control has been changed from Danfoss Control (Service Part No. 9041096-01) to WILSPEC (Service Part No. 9041106-01).

The Danfoss (Service Part No. 9041096-01) is No Longer Available. The functionality of this pressure control does not change. Both controls have the same mounting hole and terminals.

Service Part Numbers

<u>Danfoss Mfg. Control</u>	<u>WILSPEC Mfg. Control</u>	<u>Pressure Settings</u>
IOM PN.9041096-01=NLA	IOM PN. 9041106-01	200 PSI Open/250 PSI Close

